



Post Box :- 520
Telephone :- 25501000

PUNE MUNICIPAL CORPORATION

SHIVAJINAGAR, PUNE - 5.

OFFICE OF THE CHIEF FIRE OFFICER
CENTRAL FIRE STATION,
MAHATMA PHULE PETH,
PUNE - 411 042. Date :-

Outward No. 2450

Date :- 16/09/2025

Appendix XII

FIRE SAFETY CERTIFICATE

Certified that the M/s. Helios International School, on S. No. 7/1B/27B, Sun City Road, Wadgaon Bk., Tal. Haveli, Dist. Pune. comprised of Ground Floor + 6 Floors have complied with the fire prevention and fire safety requirements in accordance with the rule i.e. Maharashtra Fire Prevention & Life Safety Measure Act 2006 and verified by us on dated 16/09/2025 in the presence of Ms. Divya Ray (Puri) principal in charge and that the building - premises is fit for educational occupancy in the view of fire and life safety with effect from the date of this letter up to 15/09/2026 in accordance with rule and subject to compliance if the conditions laid in the Maharashtra Fire Prevention & Life Safety Measure Act 2006.

Issued on 16.09.2025 at Pune by



Prabhakar S. Umralkar
16/09/2025
(Prabhakar S. Umralkar)
Station Duty Officer
Pune Fire Brigade
Pune Municipal Corporation

To

M/s. Helios International School, on S. No. 7/1B/27B, Sun City Road, Wadgaon Bk., Tal. Haveli,
Dist. Pune



SFEPL - 012 /25-26

FORM B

Certified that I / We have carried out inspection of the Fire Prevention and Life Safety Measures installed in the following building or premises, namely*: -

SARASWATIDEVI RAMCHANDRA MITTAL FOUNDATION

Site – Helios International School, S NO 7/1B/27B, WADGAON (BK), PUNE.

I/We further certify that these installations in the above mentioned building are maintained in good repair and efficient conditions during the period 01/07/2025 To 31/12/2025 as required under the provisions of the Maharashtra Fire Prevention and Life Safety Measures Act, 2006 (Mah, III of 2007). The details of the inspection of installation carried out by me/us are mentioned in the report appended herewith.

Place: Pune

Date:

**MOHAN
MARUTRAO
JADHAV**

Digitally signed by MOHAN MARUTRAO JADHAV
DN: cn=MOHAN MARUTRAO JADHAV, o=SUMEET FIRE ENGINEERS PRIVATE LIMITED, ou=OTHERS, 2.5.4.20=d415c252e49ccb1414d7c32d4c5143e0a4a36b6a09102977a0ce2f4e4e555cf, postalCode=411038, st=Maharashtra, serialNumber=507479a3c5cd6c86447ce9f3481e7e7067f648b:60919a:4d2f445719c5a5e11, cn=MOHAN MARUTRAO JADHAV
Date: 2026.02.10 11:19:46 +05'30'

Sumeet Fire Engineers Pvt.Ltd.

Rajmohan Apartment , 3rd Floor, 34/2, 35/2, Karve Road, Garware Collage Metro Station, Pune 411004

License No :- MFS/LA/RF-153/2025/1000-131/PP-4
Govt. of Maharashtra


Principal
Helios International School
S.no. 7/1B/27B Wadgaon Bk.
Suncity Road, Anand Nagar, Pune.
CBSE Affiliation No. 1131367
UDISE No. 27251600217




SARASWATIDEVI RAMCHANDRA MITTAL FOUNDATION
 Site – Helios International School, S.NO.7/1B/27B, WADGAON (BK), PUNE.

INSPECTION REPORT WITH ACTIVE FIRE FIGHTING SYSTEM FOR COMMERCIAL BLD

Sr. No.	Description	Riser 1	Riser 2
1	6" Dia Riser, GI C Class Pipe	1 nos	1 nos
2	Booster Pump 900 LPM	1 nos	1 nos
3	DOL Starter for Booster Pump	1 nos	1 nos
4	Butterfly Valve 150 mm for Riser	1 nos	1 nos
5	Butterfly Valve 100 mm for Booster Pump	1 nos	1 nos
6	NRV 100 mm for booster pump	1 nos	1 nos
7	Hose Box	7+4	7+4
8	Hose Pipe	7+4	7+4
9	Branch Pipe	7+4	7+4
10	Hydrant Valve	7+4	7+4
11	Fire Hose Reel with Rubber Hose Pipe	7 nos	7 nos
12	Service Inlet	Provided	
13	Main Fire Pump 2250 LPM -2 Nos	Provided	
14	Jockey Pump 180 LPM - 1 Nos	Provided	
15	Main Fire Pump Control Panel	Provided	
16	ABC Type Fire Extinguisher 4 kg	14 nos	
17	CO2 Type Fire Extinguisher 4.5 kg	1 nos	
18	Sprinkler System provided in Basement Floor	Provided	
19	PA System	Provided	

The above installation has been tested and demonstrated to the concerned owner to his aspects

For- Sumeet Fire Engineers Pvt. Ltd.

OHAN MARUTRAO JADHAV

